

ALLWEST

DAILY PROJECT FIELD REPORT

Project: 500 Blk 3rd	Street				Project #: 321-055T					
Project Address: 500	blk 3rd Street	, Lewiston, II	D							
Permit #: N/A					Date: 4/6/2021 Page 1 of 2					
Report #:	Technicia	n: Allison Zag	jer		Weather: Warm					
Type of Testing / Insp	pection: S	oils Density Te	esting							
Deficiencies Noted:	X	No		Yes	If yes, explain below					
Deficiencies Correcte	ed:	Yes Dat	te of Correcte	ed Report(s):						
Reported To: Garrer)			of City of Le	wiston					
Narrative: ALLWEST arrived on the east side of 3rd S Field Density Test Re arriving on site.	treet. Density to	ests performed	d appeared to	be in general confo	rmance with pro	ject requirement	s. Please refer to			
Technician:	Alli Z	agez		Received By:						
This report shall countersig	eliminary until n /EST Project Ma		Reviewed By:		Zan Fisher					
Employee Type	Activity	Hours	Miles		Eq	uipment				
ST	COMPT	2	n/c	Equipment Consumables U		Nuclear Densc	meter			
				Equipment Consumables U						
				Equipment Consumables U						
Field Samples Obtained				·						

This report shall not be reproduced except in full without the permission of ALLWEST.



Field Density Test Report for Soils ASTM D 6938 / AASHTO T 310

Page 2 of 2

Projec	t Name:500 Blk 3rd Stree	et						Proje	ect #: 321-0	55T
Date: 4/6/2021 Weather: Warm					Test Metho	od:AASH1	O T 310	Gauge: 3828		
Location: Lewiston, ID						nician: Allis	son Zager		Calib. Date:	
Contractor: City of Lewiston						M.S.:		98	D.S.: 2654	
Proctor Number & Soil Description								/laximum Density	Standard/Modified	
1						7.9		141.4		
2										
3										
Elevati	SG = Finished Subg AC = Finished Asph	rade, SB = Finished S alt Grade, FG = Finish	ub-base Cour ed Grade. ("+	se, FB = Finish / -" preceedin	ned Base Cou g any elevatio	rse, LG = Finis n indicates abo	hed Lot Grad	e, FTG = Finish licated elevation	ned Footing Grant n element)	ade,
Test Numbe	Test Locati	on	Elevation	Proctor Number	Probe Depth	% Moisture	Dry Density	/ Compaction	Required Compaction	Re-Test of Test No.
1	140'S of 5th Street in	tersection	FB-2'	1	6	6.7	136.9	97	95%	
2	135'S of 5th Street in	tersection	FB-1'	1	6	5.6	135.2	96	95%	
3	125'S of 5th Street in	tersection	FB	1	6	5.6	139.9	99	95%	

This test report shall not be reproduced except in full without the permission of ALLWEST.

Report #: