



STATE OF IDAHO

DEPARTMENT OF
ENVIRONMENTAL QUALITY

1118 F Street Lewiston, Idaho 83501 (208) 799-4370
www.deq.idaho.gov

Brad Little, Governor
Jess Byrne, Director

March 25, 2021

Bryan Lacy
City of Lewiston
PO Box 617
Lewiston, ID 83501
BLacy@CityofLewiston.org

Subject: Construction Approval – TD-3 Distribution Main Replacement Phase I-III, City of Lewiston

Dear Mr. Lacy:

The Idaho Department of Environmental Quality (DEQ) received the following plans and specifications:

- TD-3 Distribution Main Replacement Phase I dated March 3, 2021 and prepared by Alannah Bailey, PE.
- TD-3 Distribution Main Replacement Phase II dated March 3, 2021 and prepared by Alannah Bailey, PE.
- TD-3 Distribution Main Replacement Phase III dated March 3, 2021 and prepared by Alannah Bailey, PE.

These projects generally include contiguous water main replacement in accordance with the City's approved facility plan. We have reviewed the plans and specifications and determined they appear to meet DEQ rules¹. The project is approved based on the conditions listed below:

Standard Conditions:

1. If construction is not completed within one year of the date of this letter, the DEQ construction approval expires. Plans and related documents may need to be resubmitted to DEQ for review and approval before further construction may proceed.
2. Any material deviations or changes that would result in a deviation from Idaho rules must be reviewed and approved by this office prior to construction.
3. The owner is required to maintain one copy of the approved plans and specifications and the DEQ approval letter on-site during construction at all times.
4. Construction must be inspected by an Idaho licensed Professional Engineer or designee to the extent required to confirm material compliance with approved plans. Within 30 days after

¹ IDAPA 58.01.08 – Idaho Rules for Public Drinking Water Systems

Mr. Lacy
March 25, 2021
Page 2

construction, record drawings, or a statement of material compliance, must be submitted to DEQ by an Idaho licensed Professional Engineer representing the system.

If you have any questions or concerns, please contact me at (208) 799-4370 or nicolas.hiebert@deq.idaho.gov.

Regards,



Nicolas Hiebert, PE
Senior Water Quality Engineer

c: Alannah Bailey, PE, City of Lewiston
Michael Camin, PE, DEQ
Hannah Erickson, EIT, DEQ
Sherise Jurries, Public Health
2021AGD1693